



CODEMARK™

CERTIFICATE OF CONFORMITY

This is to certify that



Altis Anti Termite Irrigation System

Product description

Complies with the Building Code of Australia (BCA):

1. Volume One: BP1.1 and BP1.2 *(limited only to actions by subterranean termites)*
2. Volume Two: P2.1 *(limited only to actions by subterranean termites)*
3. State Additions: Volume Two: QLD P2.1.1 *(limited only to actions by subterranean termites)*

Altis Anti Termite Irrigation System

Subject to the following conditions and limitations:

1. The Altis Anti Termite Irrigation System is to be installed by licensed installers trained and approved by Altis Pty Ltd.
2. The Altis Anti Termite Irrigation System is to be installed in accordance with the Installation and Injection procedures for Altis Anti Termite Irrigation System, version 2.11.
3. When used in conjunction with a concrete slab, the concrete slab must be designed and constructed in accordance with the requirements of AS 2870-1996 Residential slabs and footings *(as amended up to and including Amendment 4)* or AS 3600-2001 - Concrete Structures *(as amended up to and including Amendment 2)*.
4. This certification covers The Altis Anti Termite Irrigation System only when used with the following chemicals:
 - Maxxthor 100 water-based T and I by Ensystex Australia Pty Ltd, APVMA product number 60113
 - Biflex ultra-lo-odour T and I by FMC Australasia Pty Ltd, APVMA product number 59269
 - Biflex Aquamax Insecticide by FMC Australasia Pty Ltd, APVMA product number 60678
 - Premise 200 SC termiticide by Bayer Cropscience Pty Ltd, APVMA product number 49098
 - Termidor residual termiticide **(external perimeter only)** by BASF Australia Ltd, APVMA product number 54624
 - Prothor 200 SC termiticide by Ensystex Australia Pty Ltd, APVMA product number 60558
5. Inspections are undertaken annually in accordance with the Installation and Injection procedures for Altis Anti Termite Irrigation System, version 2.11 to determine that no bridging or breaching of the barrier has occurred.

Product purpose or use

Perimeter, underslab and penetrations chemical reticulation system to deter concealed entry by subterranean termites into a building.

Certificate holder

Altis Pty Ltd

ABN 39 050 495 399

12/547 Kessels Auto Park Kessels Rd

MacGregor QLD 4109

Codemark certification body

SAI Global Certification Services Pty Limited

(ACN 108 716 669) Trading as "SAI Global"

JAS-ANZ Accreditation No. Z1440295AS

Address: 286 Sussex Street, Sydney, NSW 2000

Website: www.saiglobal.com

Alex Ezrakovich

General manager Certification
For and on behalf of SAI Global

**Unrestricted
Building Certifier**

29/11/2010

Date of issue

28/11/2013

Date of expiry

CM20007

Certificate Number



JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER

- This Certificate of Conformity is issued under arrangement with JAS-ANZ. The ABCB does not in any way warrant or represent that the Product the subject of this Certificate of Conformity conforms with the BCA, nor accepts any liability arising out of the use of the Product.
- It is advised to check that this Certificate of Conformity is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the ABCB website, www.abcb.gov.au.